

Document of Certification

Controlled Environments Group, LLC.
Houston, Texas 77084

Certifies that the Cleanrooms of the

NovoSci™

Have been tested and certified in accordance with ISO 14644-1:2015 for Airborne Particulate Cleanliness Classes in Cleanrooms to meet ISO Class 7 and ISO Class 8 at .5 μm air cleanliness requirements during an "AT REST" occupancy state. The certified Cleanrooms are as follows:

GOWNING ROOM – ISO CLASS 8 AT 0.5 μm

MEDIUM CLEANROOM – ISO CLASS 7 AT 0.5 μm

LARGE CLEANROOM – ISO CLASS 7 AT 0.5 μm

SMALL CLEANROOM – ISO CLASS 7 AT 0.5 μm

Certification Testing Manager: Bernie Barela



Certification Date: 13 May 2022

